



iota VaporTite – V005

Enhanced Piping Test

We are pleased to let you know that the referenced piping has been approved for iota V005 ELD testing. The test sample provided to us meets or exceeds the 0.005 gallon per hour leak rate standard for post installation testing in California.

**OmegaFlex
DoubleTrac
Pipe**



has been approved for the iota VaporTite - V005 testing.

June, 13th 2008

800-288-2657 - <http://www.iotaleakdetection.com> - info@iotaleakdetection.com
P.O. Box 1489 Fort Collins, CO 80522