



OFFICE OF INSURANCE AND SAFETY FIRE COMMISSIONER

RALPH T. HUDGENS
COMMISSIONER OF INSURANCE
SAFETY FIRE COMMISSIONER
INDUSTRIAL LOAN COMMISSIONER
COMPTROLLER GENERAL

SEVENTH FLOOR, WEST TOWER
FLOYD BUILDING
2 MARTIN LUTHER KING, JR. DRIVE
ATLANTA, GA 30334
(404) 656-2056
www.oci.ga.gov

February 1, 2016
OmegaFlex, Inc.
Attn: Dean Rivest
451 Creamery Way
Exton, PA 19341-2509

Mr. Rivest,

It has been determined that the OmegaFlex flexible piping product will be accepted for use aboveground as fuel oil piping for generator fuel systems within Georgia by the State Fire Marshal's Office when the following conditions are met:

- 1) The piping shall only be accepted for aboveground use as fuel supply piping for Class II liquids for generator systems at this time. This product will not be accepted for aboveground use with dispensing systems at this time or aboveground use for any system for Class I liquids.
- 2) Product installation shall be in accordance with applicable editions of NFPA 30, NFPA 37, and the manufacturer's installation instructions.
- 3) Each submittal to the State Fire Marshal's Office for facilities incorporating this product must include the manufacturer's installation instructions.
- 4) Each submittal to the State Fire Marshal's Office for facilities incorporating this product must include a statement bearing the seal and registration number of a P.E. attesting that this product meets or exceeds the intent of ASME B31.
- 5) All aboveground fuel piping must be painted a light-reflective color.

This letter shall not in any way constitute an "approval" of this product by the Georgia State Fire Marshal's Office. This is only a notification of acceptance of the product for conditional use within the State. Please feel free to contact me if I can be of any further assistance. Additionally, the product has been listed in accordance with the standards of UL 971, which are accepted for underground use.

Sincerely,

Jason Pritchett
Fire Safety Compliance Officer
Georgia State Fire Marshal's Office
404-357-4340
jpritchett@sfm.ga.gov