

**OmegaFlex, Inc.**  
**451 Creamery Way**  
**Exton, PA 19341**  
**www.omegaflex.com**

We are pleased to notify you that the DoubleTrac® flexible underground piping system test sample has met tracer permeation laboratory product testing and is Tracer Tight® compatible. The sample was tested and meets or exceeds the Praxair standard of 0.005 gallons per hour (0.0013 liters per hour).

Tests Conducted:

Test	Result
Vacuum Decay	Pass
Pressure Decay	Pass
Tracer Tight®	Pass
Helium	Pass



Dan Evans  
Technology Manager  
Praxair Services, Inc.  
3755 N. Business Center Dr.  
Tucson, AZ 85705  
USA



Dirk B. Anderson  
General Manager  
Praxair Services, Inc.  
3755 N. Business Center Dr.  
Tucson, AZ 85705  
USA

